



FIRE ALARM SCHEDULE

INTERFACE REQUIREMENTS

SYSTEM - INTERFACE TO LANDLORD'S
- INTERFACE TO HVAC PANEL

FIRE FIGHTING EQUIPMENT & SIGNS

	WATER FIRE EXTINGUISHER & SIGN
	CARBON DIOXIDE EXTINGUISHER & SIGN
	AFFF FOAM FIRE EXTINGUISHER & SIGN
	FIRE BLANKET & SIGN
	FIRE DOOR KEEP SHUT
	FIRE EXIT KEEP CLEAR
	FIRE DOOR KEEP LOCKED SHUT
	FIRE SAFETY SIGN

FIRE ALARM SYSTEM

A Fire Alarm system will be installed to BS 5839 : Part 1, 2013 Code of Practice for system design, installation, commissioning and maintenance, comprising of devices as indicated, in non-domestic premises. The system category is to be an L2 system.

	Fire Alarm Panel
	Magnetic Door Hold
	Manual Call Point
	Heat Detector
	Smoke Detector
	Indicator For Void detector
	Indicates Void Detector
	Combined Smoke Detector & Zenon Beacon
	Zenon Beacon
	Sounder/Sounder Base

EMERGENCY LIGHTING SYSTEM

An independent self-contained non-maintained system, type XOA180, will be installed in accordance with BS 5266-1:2011, Emergency Lighting - Part 1 : Code of Practice for Emergency Lighting of premises other than cinemas and certain other specified premises for entertainment, and BS EN 50172 : 2004, BS 5266-8 : 2004 Lighting Applications - Emergency Lighting. Luminaires will be located in the approximate positions indicated on this drawing. All signs and notices will comply with BS 5499 : Part 1 - Fire Safety Notices and Graphic Symbols.

	3 hr maintained exit legend FoH - Channel 'Razor' BoH - Channel 'Alpine'
	3 hr non-maintained Channel 'Meteor' Surface Bulkhead
	3 hr non-maintained Channel 'Safe Spot' 3W Recessed, To FOH surface mounted to BOH
	3 hr non-maintained Channel 'Glide' 1W Recessed
	3hr non-maintained Channel 'SoHo' LED luminaire with PIR - E/SOHO/M3MW
	3 hr maintained external Channel 'Brooke' Surface Bulkhead
	3 hr non-maintained flood Channel 'Grove'

FIRE ALARM PANEL
Split box with fused isolator and DP key switch to be installed for Fire Alarm Panel

THE LOCATION AND TYPE OF ANY FIRE SAFETY AND ANY OTHER SAFETY EQUIPMENT IS SHOWN AS AT PRESENT. THIS MAY BE VARIED FROM TIME TO TIME WITH THE AGREEMENT OF THE FIRE OFFICER OR AFTER A FIRE RISK ASSESSMENT.

TOTAL AREA OF RED LINE (LICENSABLE ACTIVITIES)

INTERNAL = 2662 SQ FT OR 69 SQ M

EXTERNAL = 275 SQ FT OR 25 SQ M

RED LINE INDICATES EXTENT OF AREA FOR LICENSABLE ACTIVITIES

Revisions

REV	DATE	INT.	DESCRIPTION
XX	XXXX_XX_XX	XX	XXXXXXXXXXXX



turnerbates
DESIGN & ARCHITECTURE

Design Intent Drawing. Do not scale. All dimensions to be checked on site. This drawing is the sole copyright of Turner Bates and is not to be reproduced without permission.

All survey information used in this drawing was provided by ACUBENT FULL NAME. All areas and measurements to be checked on-site.

PROJECT CLIENT: THE ALCHEMIST

PROJECT: CHELTENHAM BREWERY QUARTER

ADDRESS: UNIT 8, CHELTENHAM BREWERY QUARTER, CHELTENHAM, GL50 4FA

STATUS: FOR LICENSING

PROPOSED LICENSING PLAN

Figured dimensions take precedence over scale dimensions. Contractors must verify all dimensions on site before commencing any work or making shop drawings.

SCALE @A3	DATE	DRAWN	CHECKED
1:100	09/19	AJ	JG
PROJECT NUMBER	DRAWING NUMBER	REVISION	
TB_19_1716	500	100	